

| | | | |
|--|---------------------------------|---|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | 1. CONTRACT ID CODE | |
| 2. AMENDMENT/MODIFICATION NO. 02 | 3. EFFECTIVE DATE 09/08/2009 | 4. REQUISITION/PURCHASE REQ. NO. BG 090203 | 5. PROJECT NO. (If applicable) BG 090203 |
| 6. ISSUED BY AOC - Procurement Division 2nd & D Streets, SW Room H2-263 WASHINGTON, DC 20515 | CODE 9901 | 7. ADMINISTERED BY (If other than Item 6) | CODE |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, country, state and ZIP Code) | | (X) | 9A. AMENDMENT OF SOLICITATION NO. RFP090051 |
| | | X | 9B. DATED (SEE ITEM 11) 08/24/2009 |
| | | | 10A. MODIFICATION OF CONTRACT/ORDER NO. |
| | | | 10B. DATED (SEE ITEM 11) |
| CODE | FACILITY CODE | | |

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.

IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

| | |
|-----------|---|
| CHECK ONE | A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. |
| | B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). |
| | C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: |
| | D. OTHER (Specify type of modification and authority) |

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

This Amendment No. 2 is being issued to respond to questions received to date.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

| | | | |
|---|------------------|--|----------------------------|
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Lauren Wilson Contracting Officer | |
| 15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign) | 15C. DATE SIGNED | 16B. UNITED STATES OF AMERICA By  (Signature of Contracting Officer) | 16C. DATE SIGNED 9/8/09 |

NSN 7540-01-152-8070
Previous edition unusable

STANDARD FORM 30 (REV. 10-83)
Prescribed by GSA FAR (48 CFR) 53.243

RFP090051

“U.S. BOTANIC GARDEN TERRACE GARDEN (RAIN GARDEN)”
RFP NO. 090051

Questions and Government Responses

Question 1: Please confirm we are pricing Phase A only. In the meeting this was requested, but the drawings show all phases. Not sure if you wanted all pricing broken out by phase.

Response: Pricing is for Phase A only. The General Requirements and Summary of Work outline the work associated with this solicitation.

Question 2: In the site meeting it was verbally stated the existing plants would be removed by another contractor along with the temporary display. Please confirm this is the case, since the demolition drawing does not show any demolition for phase A other than protecting the existing trees and note 2 for the yard hydrant.

Response: Yes, existing plants will be removed by others, all but the turf and trees shown on the plans. See specification Section 011000 - Summary of Work, Part 1.6, Work By Government.

Question 3: In the meeting it was discussed that a construction fence should be provided around phase A with slats. Please confirm 6 foot high metal fence with blocks and visibility slats are to be provided.

Response: See General Requirements - Section 010000, page 18, Baricades and Fences for details; the fence is to be 8 foot high.

Question 4: Is any yard inlet protection required? I could not find any reference to specific yard inlets and the type of protection for phase A.

Response: There are not any existing yard inlets in phase A, a perimeter silt fence is required in locations shown on sheet C103 of the construction drawings; see sheet C501 and the specifications for details.

Question 5: Please note the solicitation calls for 6 options while the specifications call for two. Per the meeting we will proceed with the 6 as discussed.

Response: Please price all that are listed, there are 2 Options and 3 Unit Prices, the two may have been confused.

Question 6: Is the government providing the testing for concrete and soil compaction or is this to be provided by the contractor?

- Response: Contractor is to provide the required submittals as detailed in the specification sections through independent testing laboratories (e.g., concrete cylinder test results, density and moisture soil tests reports).
- Question 7: How many days are required to notify the contractor of a change? This is blank on page 17 of 57.
- Response: This clause does not apply. Remove from Solicitation.
- Question8: On page 18 of 57 the number of days the contracting officer has to respond to a change is blank. Please provide.
- Response: This clause does not apply. Remove from Solicitation.
- Question 9: On pg 32 of 57 submittals is discussed. Please confirm the turnaround time for the A/E for the project. The time frame from award to start of construction is only a month. Submittals need to be turned around in 5 days by the A/E. Please confirm.
- Response: Review can be expedited and returned within 5 days of receipt for items marked 'Critical'.